



Alucoil  
Grupo Alibérico  
Pol. Ind de Bayas  
C/Ircio, parc. R72-R77  
09200 Miranda de Ebro (Burgos)  
SPAIN

ZENTRALE:  
A-4017 LINZ, PETZOLDSTRASSE 45, POSTFACH 27  
TELEFON: 0732/7617-850, FAX: 0732/7617-89  
www.ibs-austria.at - office@ibs-austria.at

BANKVERBINDUNGEN:  
HYPO OBERÖSTERREICH, KTO.-NR. 00 0021294 4, BLZ 54000  
IBAN: AT46540000000212944, SWIFT: OBLAAT2L  
OBERBANK LINZ, KTO.-NR. 621-0060/55, BLZ 15000  
DVR: 0659959, FN 89116d REGISTERGERICHT LINZ, UID-NR. ATU 23289705

20<sup>th</sup> May 2011  
Bearbeiter:  
Herr Andexlinger/am  
DW 868

### Confirmation for classification report No. 25422-2 D M1

This document confirms the validity of the above mentioned classification report for Austria.

Applicant: Alucoil  
Grupo Alibérico  
Pol. Ind de Bayas  
C/Ircio, parc. R72-R77  
09200 Miranda de Ebro (Burgos) Spain

Product: Iarcore<sup>®</sup> A2 Aluminum honeycomb plate

Structure of product: Aluminum composite slab with aluminum honeycomb on the inside (bee honeycomb) reciprocally stuck together and reciprocally coats

Test institut: Tecnalia Research & Innovation  
Área anardi, 5  
E-20730 Azpeitia (Gipuzkoa)


Classification report Nr. 25422-2 d M1 (EN 13501-1) based on the test report No. 25422-1-d M1 (EN ISO 1716 and EN 13823).

After examination of the available documents the behaviour in case of fire class can be confirmed as **A2-s2, d0**.

Kind regards  
**IBS-INSTITUT FÜR BRANDSCHUTZTECHNIK UND  
SICHERHEITSFORSCHUNG GESELLSCHAFT M.B.H.**  
Akkreditierte Prüf- und Inspektionsstelle

  
R. ANDEXLINGER  
Official in charge

  
Ing. J. STOCKINGER  
Sub-area manager, Testing Institute

  
Dir. Stv. Ing. H. PEHERSTORFER  
Authorised officer  
Managing director